


Declaration of Product

We the Manufacturer

SHENZHEN GROWATT NEW ENERGY TECHNOLOGY CO., LTD

Declare all Growatt inverters listed below equipped with DC insulation resistance detection circuit, according VDE V 0126-1-1:2006-02, the insulation resistance must be $\geq 1\text{k}\Omega/\text{V}$ related to maximum inverter input voltage, therefore, when choose safety standard VDE 0126, inverter DC leakage current is lower than 1mA.

- Growatt 750-S, Growatt 1000-S, Growatt 1500-S, Growatt 2000-S, Growatt 2500-S
Growatt 3000-S
- Growatt 2500MTL-S, Growatt 3000MTL-S, Growatt 3600MTL-S, Growatt 4200MTL-S, Growatt 5000MTL-S, Growatt 5500MTL-S.
- Growatt 3000TL3-S, Growatt 4000TL3-S, Growatt 5000TL3-S, Growatt 6000TL3-S
- Growatt 7000TL3-S, Growatt 8000TL3-S, Growatt 9000TL3-S, Growatt 10000TL3-S,
- Growatt11000TL3-S, Growatt12000TL3-S, Growatt13000TL3-S, Growatt 15000TL3-S
- Growatt 30000TL3-S, Growatt 33000 TL3-S, Growatt 40000TL3-NS, Growatt 50000TL3-S.
- MAX 50KTL3 LV, MAX 60K TL3 LV, MAX 70KTL3 LV, MAX 80KTL3 LV



R&D Director

Shenzhen Growatt New Energy Technology CO., LTD

2019.4.26