

ShortBus Modbus Scanner v2.5 - Read Window 1

Connection: COM3 Node Address: 1 Read Function: FC 4 - Read 3x (Input Registers)  
Baud: 115200 Starting Address: 50 0-Based Hex Result Format: Floating Point  
Parity: None Length To Read: 10 Char Delay (ms): 250 Byte Order: Normal  
Stop Bits: 1 Poll Delay (ms): 1000 Word Order: Normal

Log Name (double-click for prompt): output.txt Log Append:  Start Log End Log

Connect Disconnect  
Total Polls: 803 Valid Polls: 802 Reset Poll Counters  
Open New Read Window Write Multiple

**No Error**  
**DOUBLE-CLICK VALUE TO DISPLAY WRITE WINDOW**

300050:	0
300051:	n/a
300052:	0
300053:	n/a
300054:	22,625
300055:	n/a
300056:	20,029
300057:	n/a
300058:	4,408065E-41
300059:	n/a